



RTD ELEMENT RESISTANCE @ 0°C = 1,000 Ω ± 0.06%
 RTD ELEMENT ACCURACY @ 0°C = ± 0.30°C
 TCR = 3,850ppm/°C
 DIN43760 ACCURACY CLASS = "B"
 TEMPERATURE RATING = -50 TO +105°C

MOUNTING HOLE DIAMETER = 0.171" ± 0.008"
 MOUNTING HOLE STUD SIZE = #8

SEE MANUFACTURING SPECIFICATION (LAYER 1)

| | | | |
|------|-----------------------|----------|-----|
| NONE | RELEASE TO PRODUCTION | 08/31/06 | DD |
| REV | REVISION RECORD | DATE | APP |

| | |
|-------------------------|--|
| SCALE NONE | U.S. SENSOR CORP. 1832 W. COLL INS AVE. ORANGE, CA. 92867 714-639-1000 www.ussensor.com |
| DRAWN BY DAN DANKERT | |
| DATE 08/31/06 | RTD PROBE |
| REV. NONE | P/N USW2299 |
| LAYER 0 OF 2 | |