

## Product Change Notice

PCN#: EE-PCN21009

04/26/2021

### CLASSIFICATION OF CHANGE:

Voltage rating increase for the HHT fuse holder.

### DESCRIPTION OF CHANGE:

Part Number	Voltage Rating	
	Previous	New
BK-HHT	250 Vac	600 Vac
HHT	250 Vac	600 Vac

### REASON FOR CHANGE:

Through continuous improvement efforts, Eaton has achieved a higher voltage rating for its HHT family of fuse holders. This family can now be applied in more applications due to this increase in voltage rating.

### EXPECTED INFLUENCE ON QUALITY, RELIABILITY, AND PERFORMANCE:

Other than the increase in voltage rating, there will be no effect on the quality, reliability or performance. There are no changes to form, fit or function of the devices.

### PARTS FAMILIES AFFECTED

HHT fuse holders in both standard and bulk packaging. See table above for specific part numbers. The latest datasheet is available [here](#).

### TIME SCHEDULE:

This change takes effect immediately.

### SAMPLE AVAILABILITY:

Available upon request.

### ISSUED BY:

Jenan Krouchick  
Product Manager – Circuit Protection

### CONTACT INFORMATION:

For questions or comments, please contact <https://www.eaton.com/content/eaton/us/en-us/products/electronic-components/contact-us.html>