



8755 W. Higgins Road Suite 500 Chicago, IL 60631

Product/Process Change Notice (PCN)

PCN#: LFPCN41240 **Date:** Jan 8th, 2016

Product Identification:

Voltaje improvement for 0254, 0356 and 0359 Series

Implementation Date for Change:

February 8th, 2016

Contact Information

Name: Aurora Contreras

Title: Assistant Product Manager

Phone #: +52 (878) 782 6222 ext. 4796

Fax#:

E-mail: acontreras@littelfuse.com

Category of Change:

- Assembly Process
- Data Sheet
- Technology
- Discontinuance/Obsolescence
- Equipment
- Manufacturing Site
- Raw Material
- Testing
- Fabrication Process
- Other: _____

Description of Change:

Littelfuse Product Management would like to inform you that in order to improve according the market demands we are improvement the operating voltage rating for 0254, 0356 and 0359 Series.

There are no changes in form and fit. The operating rating is improved from 300 V up to 400 V for the 0254 Series; certified by UL. The voltage mark will be changed from "300 V" to "400 V" on the holder's plastic body.

For the 0356 Series: There are no changes in form and fit. The voltage rating is improved to 600V certified by UL.

The 0359 Series: There are no changes in form and fit; new UL recognition to 600V and 30A operating rating.

Important Dates:

- Qualification Samples Available: 1/11/2016 Last Time Buy:
- Final Qualification Data Available: Upon request
- Date of Final Product Shipment: 2/5/2016

Method of Distinguishing Changed Product

- Product Mark, For 254 Series
- Date Code,
- Other, For 0356 and 0359 Series the description on the label will be change

Demonstrated or Anticipated Impact on Form, Fit, Function or Reliability:

NA

LF Qualification Plan/Results:

Upon Request

Customer Acknowledgement of Receipt: Littelfuse requests you acknowledge receipt of this PCN. In your acknowledgement, you can grant approval or request additional information. Littelfuse will assume the change is acceptable if no acknowledgement is received within 15 days of this notice. Lack of any additional response within 30 days of PCN issuance further constitutes acceptance of the change.